



**Uniform Building Code Commission
Staff Comment Form - [FGMP 38](#)**

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 5/17/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: FGMP 2018

Code Modified: 2018 IPC

Original Comment Form Number: SCF 52

Rule Number: 748:20-16-13

Which area of the code (Section, Table, Figure) was revised?

Chapter 8, Section 802.1

Page Number: 8-1

Previous Change:

Section 802.1 Where required. Food Handling equipment, in other than dwelling units, clear-water waste, humidifiers, dishwashing machines and utensils, pots, pans and dishwashing sinks shall discharge through an indirect waste pipe as specified in Sections 802.1.1 through ~~802.1.8~~ 802.1.7. Fixtures not required to be indirectly connected by this section and the exception to Section 301.6 shall be directly connected to the plumbing system in accordance with Chapter 7.

Historical information

This change was made by the 2018 FGMP to address errata published by the ICC. The change has been corrected in the 2021 code. Staff recommendation is to delete the modification from the agency's rules.