



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [FGMP 42](#)

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 5/17/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: FGMP 2018

Code Modified: 2018 IPC

Original Comment Form Number: SCF 54

Rule Number: 748:20-16-16 (2)

Which area of the code (Section, Table, Figure) was revised?

Chapter 11, Section 1101.9

Page Number: 11-1

Previous Change:

Section 1101.9 Backwater valves. Storm Drainage systems shall be provided with backwater valves as required for sanitary drainage systems in accordance with Section ~~715~~ 714.

Historical information

This section was modified to address errata published by the ICC. It has been corrected in the 2021 code and staff recommendation is to delete the modification from the agency rules.