

OKLAHOMA

Uniform Building Code Commission Technical Code Review Committee

Public Comment Form

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

INSTRUCTIONS:

1. Please type or print clearly.
2. Form must be signed. Any forms that are not signed or filled out completely, may not be considered.
3. Each requested change must be on a separate form.
4. If the space to show the proposed change or supporting information is not big enough to show the entire change, write the words "See Attached" in the space provided and submit the change on a separate page.

Contact Information:

Name JW Williams

Address 3424 Shell Lane

City Yukon State OK Zip 73099

Email Address williamsjw@cvtech.edu Phone Number 405-229-5129

Code Change Information:

Will this change increase the cost of construction? Yes No

Which code needs to be revised? IMC® 307.2.1 Condensate disposal

Which section of the code needs to be revised?

Section 307.2.1 Table _____ Figure _____ Page _____

Proposed Change:

Show the proposed new, revised, or deleted text in Legislative format. Line through text to be deleted and underline text to be added or revised.


This should be added to existing rule in IMC, IFGC, and IPC. The condensate drain termination should be below ground within 1" of fill gravel. Drain should be protected from freezing where exits building to 12" below ground

Supporting Information:

State the purpose and reason for the change and provide substantiation to support the proposed change.

Existing rule does not state where drain must terminate into pit and does not address freeze protection for outside drain

Signature: _____



Date: 10/31/23

Send completed form to:
Oklahoma Uniform Building Code Commission
2401 N.W. 23 St, Ste 82, Oklahoma City, OK 73107
Or email to Kathy.Hehnl@oubcc.ok.gov or Lindsay.Heinrichs@oubcc.ok.gov