



# OKLAHOMA

## Uniform Building Code Commission Staff Comment Form - FGMP 5

### FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

#### Contact Information:

Name: OUBCC Staff

Date 5/15/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

#### Code Change Information

Originating Committee: FGMP-2009

Code Modified: 2018 IFGC

Original Comment Form Number: FGMP-78  
& 89

Rule Number: 748:20-12-9 (1)

Which area of the code (Section, Table, Figure) was revised?

IFGC Ch 4, Section 404.12

Page Number: 4-43

#### Previous Change:

**404.12 Minimum burial depth.** Underground piping systems shall be installed a minimum depth of ~~12~~ 18 inches (~~305~~ 457 mm) below grade, except as provided for in Section 404.12.1. Exception: Where a minimum depth of cover cannot be provided, the pipe shall be installed in conduit or bridged (shielded).

#### Historical information

The section was originally modified in the 2009 adoption and further modified in the 2015 adoption. The 2018 committee felt the change should be kept.