



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - FGMP 7

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 5/17/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: AFPTC 2015

Code Modified: 2018 IFGC

Original Comment Form Number: AFPTC 2

Rule Number: 748:20-12-9 (5)

Which area of the code (Section, Table, Figure) was revised?

IFGC Ch 4, Section 413.3.2

Page Number: 4-52

Previous Change:

413.3.2 Warning signs. Warning signs complying with Section 310 of the International Fire Code® shall be posted as follows:

(A) Warning sign(s) shall be conspicuously posted within sight of each dispenser in the fuel dispensing area and shall state the following:

(i) No smoking (ii)

Shut off motor

(iii) Flammable Gas

(iv) Natural gas vehicle fuel cylinders shall be inspected at intervals not exceeding 3 years or 36,000 miles to ensure safe operation of the vehicle

(v) Natural gas fuel cylinders past their end-of-life date shall not be refueled and shall be removed from service.

(B) A warning sign with the words "NO SMOKING, FLAMMABLE GAS" shall be posted in all compressor and storage areas.

(C) The lettering on the sign shall be legible and large enough to be visible from each point of transfer.

(D) The service pressure of each dispenser shall be posted in view of the operator

Historical information

This section was added to require warning signs be posted on Compressed Natural Gas (CNG) dispensing devices. The change was originally made by the AFPTC and was approved by the 2018 BEBF committee to be carried forward. The section does not exist in the 2021 code. The language comes from NFPA 52.