



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - FGMP 8

FGMP Technical Committee

Review of the 2021 Editions of the International Fuel Gas Code® (IFGC®), International Mechanical Code® (IMC®), International Plumbing Code® (IPC®)

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 5/17/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: AFPTC 2015

Code Modified: 2018 IFGC

Original Comment Form Number: AFPTC 6

Rule Number: 748:20-12-9 (6)

Which area of the code (Section, Table, Figure) was revised?

IFGC Ch 4, Section 413.5

Page Number: 4-52

Previous Change:

413.5 Private fueling of motor vehicles.

(A) Self-service CNG-dispensing systems, including key, code and card lock dispensing systems, shall be limited to the filling of approved, permanently mounted fuel containers ~~on CNG-powered vehicles~~

(B) In addition to the requirements in the International Fire Code, the owner of a self-service CNG-dispensing facility shall ensure the safe operation of the system ~~and the training of users.~~

Historical information

This section was modified as while it was common to find CNG trailers utilized in various approved applications throughout the state, the vehicle pulling the trailer was not always a CNG powered vehicle and by removing the requirement it allowed for better use of the trailers. The change also clarifies that it is the responsibility of the owner or user of a vehicle to be properly trained on their vehicle's filling procedures and not the fuel station to provide necessary training.

The language in the 2021 code mirror's the 2018 language without the OUBCC modifications, however the section number has changed to 413.6.