

BEBC-110



# OKLAHOMA

## Uniform Building Code Commission Technical Code Review Committee

### Public Comment Form

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

#### INSTRUCTIONS:

1. Please type or print clearly.
2. Form must be signed. Any forms that are not signed or filled out completely, may not be considered.
3. Each requested change must be on a separate form.
4. If the space to show the proposed change or supporting information is not big enough to show the entire change, write the words "See Attached" in the space provided and submit the change on a separate page.

#### Contact Information:

Name Bryant VanFossen

Address 7 N Broadway

City Edmond State OK Zip 73034

Email Address bryant.vanfossen@edmondok.gov Phone Number 405.359.4664

#### Code Change Information:

Will this change increase the cost of construction? Yes  No

Which code needs to be revised? IBC + IFC

Which section of the code needs to be revised?

Section 1031.7, 1031.7.1 Table \_\_\_\_\_ Figure \_\_\_\_\_ Page \_\_\_\_\_

1031.7.2

**Proposed Change:**

Show the proposed new, revised, or deleted text in Legislative format. Line through text to be deleted and underline text to be added or revised.

1031.7 Openings. All R-1 occupancies shall have windows, whether operable or fixed, in all sleeping rooms below the sixth story meeting the following requirements.

1031.7.1 Minimum Size. Windows described by this Section shall have a minimum glazing area of 5.7 sq. ft.

1031.7.2 Minimum Dimensions. The minimum glazing height dimension shall be 24 inches. The minimum glazing width dimension shall be 20 inches.

**Supporting Information:**

State the purpose and reason for the change and provide substantiation to support the proposed change.

Increase efficiency in first responder entry and rescue operations.

This will need to be reflected in the IFC.

Bryant

Signature: VanFossen

Digitally signed by Bryant  
VanFossen  
Date: 2023.06.01 09:21:01 -05'00'

Date: 6/1/23

**Send completed form to:**  
Oklahoma Uniform Building Code Commission  
2401 N.W. 23 St, Ste 82, Oklahoma City, OK 73107  
Or email to [Kathy.Hehnl@oubcc.ok.gov](mailto:Kathy.Hehnl@oubcc.ok.gov) or [Lindsay.Heinrichs@oubcc.ok.gov](mailto:Lindsay.Heinrichs@oubcc.ok.gov)