BEBF-113



Uniform Building Code Commission Technical Code Review Committee

Public Comment Form

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

INSTRUCTIONS:

- 1. Please type or print clearly.
- 2. Form must be signed. Any forms that are not signed or filled out completely, may not be considered.
- 3. Each requested change must be on a separate form.
- 4. If the space to show the proposed change or supporting information is not big enough to show the entire change, write the words "See Attached" in the space provided and submit the change on a separate page.

Contact Information:

Name Bryant VanFossen			
Address 7 N. Broadway			
City Edmond	State OK	Zip <u>73034</u>	
Email Address bryant.vanfossen@edmondok	Phone Numb	Phone Number <u>405-359-4664</u>	
Code Change Information:			
Will this change increase the cost of constru	uction?	Yes ✓ No 🗌	
Which code needs to be revised? IFC			
Which section of the code needs to be revised?			
Section 507.1 Table	Figure	Page	

Show the proposed new, revised, or deleted text in Legislative format. Line through text to be deleted and underline text to be added or revised.
507.1 Required Water Supply An approved water supply capable of supplying the required fire flow for fire protection shall be provided to premises on which facilities, buildings or portions of buildings are hereafter constructed or moved into or within the jurisdiction.
Exception: Where, in the opinion of the Fire Code Official, it is not possible for an approved water supply to be brought to the building, the building must be equipped with a fire alarm system in accordance with Section 907 of the IFC with automatic smoke detection in accordance with Section 17.5.3.1 of NFPA 72 and occupant notification system in accordance with Section 907.5 of the IFC.
Supporting Information: State the purpose and reason for the change and provide substantiation to support the proposed change.
Rather than the building being completely unprotected and no early warning to the occupants or the Fire Department, provide some level of protection. This also would align with the State Fire Marshal's Directive 2013-8.

Proposed Change:

Bryant

Signature: VanFossen

Date: <u>5/19/23</u>

Digitally signed by Bryant VanFossen Date: 2023.05.19 11:45:04 -05'00'