



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [BEBF 12](#)

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 04/27/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: SSTC 2015

Code Modified: 2018 IBC

Original Comment Form Number: SSTC 7

Rule Number: 748:20-2-9 (12)

Which area of the code (Section, Table, Figure) needs to be revised?

IBC Section 423.5

Page Number: n/a

Previous change:

423.5 Required. Where storm shelters are provided, they shall be provided in compliance with ICC 500 except as required by Sections 423.6.1 through 423.6.11.

Historic information:

This language for this section was added to the code by the SSTC 2015 committee to provide charging language to allow for the code changes made by that committee to the OUBCC adopted code. The Section number needs to be changed from 423.5 to 423.6 if the changes are kept in the code.

Staff recommends keeping the charging language if all or some of the changes related to storm shelters are kept.