

OKLAHOMA

Uniform Building Code Commission Technical Code Review Committee

Public Comment Form

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

INSTRUCTIONS:

1. Please type or print clearly.
2. Form must be signed. Any forms that are not signed or filled out completely, may not be considered.
3. Each requested change must be on a separate form.
4. If the space to show the proposed change or supporting information is not big enough to show the entire change, write the words "See Attached" in the space provided and submit the change on a separate page.

Contact Information:

Name Cary Williamson

Address PO Box 249

City Ardmore State OK Zip 73402

Email Address cwilliamson@ardmorecity.org Phone Number 580-221-2550

Code Change Information:

Will this change increase the cost of construction? Yes No

Which code needs to be revised? 2021 International Building Code

Which section of the code needs to be revised?

Section 3313.2 Table _____ Figure _____ Page _____

Proposed Change:

Show the proposed new, revised, or deleted text in Legislative format. Line through text to be deleted and underline text to be added or revised.

3313.2 When combustible building materials of the building under construction are delivered to a site, a minimum fire flow of 500 gallons per minute (1893 L/m) shall be provided. The fire hydrant used to provide this fire flow supply shall be within 500 feet (152 m) of the combustible building materials, as measured along an approved fire apparatus access lane. Where the site configuration is such that one fire hydrant cannot be located within 500 feet (152 m) of all combustible building materials, additional fire hydrants shall be required to provide coverage in accordance with this section.


Exception: The fire code official is authorized to reduce the fire flow requirements or provide other water supply alternatives in rural areas or small communities where the development of full fire-flow requirements is impractical.

Supporting Information:

State the purpose and reason for the change and provide substantiation to support the proposed change.

A very large portion of the State of Oklahoma is comprised of rural areas that are not served by an established water system. In those areas, the AHJ should be allowed to approve alternatives to satisfy fire protection requirements during construction.

Signature: _____



Date: _____

10/3/2023

Send completed form to:
Oklahoma Uniform Building Code Commission
2401 N.W. 23 St, Ste 82, Oklahoma City, OK 73107
Or email to Kathy.Hehnlly@oubcc.ok.gov or Lindsay.Heinrichs@oubcc.ok.gov