



OKLAHOMA

Uniform Building Code Commission Technical Code Review Committee

Public Comment Form

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

INSTRUCTIONS:

1. Please type or print clearly.
2. Form must be signed. Any forms that are not signed or filled out completely, may not be considered.
3. Each requested change must be on a separate form.
4. If the space to show the proposed change or supporting information is not big enough to show the entire change, write the words "See Attached" in the space provided and submit the change on a separate page.

Contact Information:

Name Cary Williamson

Address PO Box 249

City Ardmore State Ok Zip 73402

Email Address cwilliamson@ardmorecity.org Phone Number 580-221-2550

Code Change Information:

Will this change increase the cost of construction? Yes No

Which code needs to be revised? 2021 IEBC

Which section of the code needs to be revised?

Section 1509.1 Table _____ Figure _____ Page _____

Proposed Change:

Show the proposed new, revised, or deleted text in Legislative format. Line through text to be deleted and underline text to be added or revised.

1509.1 When required. An approved water supply for fire protection, either temporary or permanent, shall be made available as soon as combustible building material arrives on the site, on commencement of vertical combustible construction, and on installation of a standpipe system in buildings under construction, in accordance with Sections 1509.1 through 1509.5.

Exception: The fire code official is authorized to reduce the fire flow requirements or provide other water supply alternatives for isolated buildings or a group of buildings in rural areas or small communities where the development of full fire-flow requirements is impractical.

Supporting Information:

State the purpose and reason for the change and provide substantiation to support the proposed change.

A very large portion of the State of Oklahoma is comprised of rural areas that are not served by an established water system. In those areas, the AHJ should be allowed to approve alternatives to satisfy fire protection requirements during construction.

Signature: _____ Date: 10/9/23