



# OKLAHOMA

## Uniform Building Code Commission Staff Comment Form - [BEBF 13](#)

### BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

#### Contact Information:

Name: OUBCC Staff

Date 04/27/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

#### Code Change Information

Originating Committee: SSTC 2015

Code Modified: 2018 IBC

Original Comment Form Number: SSTC 5  
R1

Rule Number: 748:20-2-9 (13)

#### Which area of the code (Section, Table, Figure) was revised?

IBC Section 423.5.1

Page Number: n/a

#### Previous change:

**423.5.1 Storm shelter documents.** The construction documents which were prepared for the construction of the storm shelter, shall be maintained and protected within the storm shelter by the owner or owner's authorized agent.

#### Historic information:

This language was added by the SSTC committee to bring the documents referenced in ICC 500 and the requirements within FEMA P 320 and FEMA P 361 in line and reduce the differences between them. The 2018 BEBF Committee chose to keep the change in the agency's rules. The language is not in the 2021 code. The section number if kept should be updated to 423.6.1

Staff recommends keeping the committee determine if the change should be kept as written, further modified, or deleted from the agency rules.