



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [BEBF 15](#)

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 04/27/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: SSTC 2015

Code Modified: 2018 IBC

Original Comment Form Number: SSTC 15

Rule Number: 748:20-2-9 (16)

Which area of the code (Section, Table, Figure) was revised?

IBC Section 423.5.3

Page Number: n/a

Previous change:

423.5.3 Roof live load reduction for shelters. Roof live load reduction in Section 1607.13.2.1 (Equation 16-26) shall not be allowed for roof live loads stipulated under ICC 500® Section 303.2.

Historic information:

This language was added by the SSTC committee to clarify the roof live load could not be reduced as allowed in the 2015 IBC Section 1607.12.2.1 (Equation 16-26). The section reference was updated in the 2018 adoption to 1607.13.2.1. The section reference and equation reference have been updated in the 2021 code to 1607.14.2.1 and Equation 16-10.

Staff recommendation is to review the language and determine if it's still needed. If needed, the motion should include updating the references to match the 2021 code. If not needed, motion should be to delete and remove from the agency rules.