



OKLAHOMA

Uniform Building Code Commission Technical Code Review Committee

Public Comment Form

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

INSTRUCTIONS:

1. Please type or print clearly.
2. Form must be signed. Any forms that are not signed or filled out completely, may not be considered.
3. Each requested change must be on a separate form.
4. If the space to show the proposed change or supporting information is not big enough to show the entire change, write the words "See Attached" in the space provided and submit the change on a separate page.

Contact Information:

Name Bryant VanFossen

Address 7 N. Broadway

City Edmond State OK Zip 73034

Email Address bryant.vanfossen@edmondok.gov Phone Number 405-359-4664

Code Change Information:

Will this change increase the cost of construction? Yes No

Which code needs to be revised? IEBC

Which section of the code needs to be revised?

Section 1509.1 Table _____ Figure _____ Page _____

Proposed Change:

Show the proposed new, revised, or deleted text in Legislative format. Line through text to be deleted and underline text to be added or revised.

1509.1 Where required. In buildings required to have standpipes by Section 905.3.1, not less than one standpipe shall be provided for use during construction. Such standpipes shall be installed prior to construction exceeding ~~40~~ 30 feet in height above the lowest level of fire department vehicle access. Such standpipes shall be provided with fire department hose connections at locations adjacent to *stairways* complying with Section 1508.1. As construction progresses, such standpipes shall be extended to within one floor of the highest point of construction secured decking or flooring.

Supporting Information:

State the purpose and reason for the change and provide substantiation to support the proposed change.

Requiring the standpipe to be operational sooner during the construction process could help immensely during the response to a fire on an active construction site.

Many large construction site fires have occurred in the state over the last 15 years or so. This would help cut down on response time.

This would need to be reflected in the IBC and potentially the IEBC as well.

Bryant
Signature: VanFossen

Digitally signed by Bryant
VanFossen
Date: 2023.05.19 11:45:04 -05'00'

Date: 5/19/23

Send completed form to:
Oklahoma Uniform Building Code Commission
2401 N.W. 23 St, Ste 82, Oklahoma City, OK 73107
Or email to Kathy.Hehnly@oubcc.ok.gov or Lindsay.Heinrichs@oubcc.ok.gov