

BEBF-158



# OKLAHOMA

## Uniform Building Code Commission Technical Code Review Committee

### Public Comment Form

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

#### INSTRUCTIONS:

1. Please type or print clearly.
2. Form must be signed. Any forms that are not signed or filled out completely, may not be considered.
3. Each requested change must be on a separate form.
4. If the space to show the proposed change or supporting information is not big enough to show the entire change, write the words "See Attached" in the space provided and submit the change on a separate page.

#### Contact Information:

Name Scott Wise

Address 420 W. Main Street

City Oklahoma City State OK Zip 73160

Email Address scott.wise@okc.gov Phone Number 405-297-2979

#### Code Change Information:

Will this change increase the cost of construction? Yes  No

Which code needs to be revised? 2024 IBC

Which section of the code needs to be revised?

Section 1110.4 Table \_\_\_\_\_ Figure \_\_\_\_\_ Page \_\_\_\_\_

**Proposed Change:**

Show the proposed new, revised, or deleted text in Legislative format. Line through text to be deleted and underline text to be added or revised.

see attached.

**Supporting Information:**

State the purpose and reason for the change and provide substantiation to support the proposed change.

The ICC is now developing new code language for adult changing stations, however, certain language is lacking regarding various details we feel necessary.

Public and private parks typically lack sufficient and clean restrooms as it is. It makes matters worse when needing to change a child or adult with special needs. Parks provide some restrooms facilities but the code does not provide specifics on the number of fixtures due to the uncertainty of the use and how to effectively measure the need. Parks tend to provide 2 to 3 fixtures per gender in areas served. This new requirement would ensure that at least one such restroom has an Adult Changing Station.

Signature: Scott Wise Digitally signed by Scott Wise  
Date: 2024.05.03 13:49:29 -05'00' Date: 5/3/24

**Send completed form to:**  
Oklahoma Uniform Building Code Commission  
2401 N.W. 23 St, Ste 82, Oklahoma City, OK 73107  
Or email to [Kathy.Hehnlly@oubcc.ok.gov](mailto:Kathy.Hehnlly@oubcc.ok.gov) or [Lindsay.Heinrichs@oubcc.ok.gov](mailto:Lindsay.Heinrichs@oubcc.ok.gov)

## CHAPTER 11. ACCESSIBILITY

### 1110.4.1 Where required.

Not fewer than one adult changing station shall be provided in the following locations:

1. In assembly and mercantile occupancies, where family or assisted-use toilet or bathing rooms are required to comply with Section 1110.2.1.
2. In Group B occupancies providing educational facilities for students above the 12<sup>th</sup> grade, where an aggregate of twelve or more male and female water closets are required to serve the classrooms and lecture halls.
3. In Group E occupancies, where a room or space used for assembly purposes requires an aggregate of six or more male and female water closets for that room or space.
4. In highway rest stops and highway service plazas.
5. Public or private parks and campgrounds.