



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [BEBF 21](#)

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 04/28/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: SSTC 2015

Code Modified: 2018 IBC

Original Comment Form Number: SSTC 11

Rule Number: 748:20-2-9 (23)

Which area of the code (Section, Table, Figure) needs to be revised?

IBC Section 423.5.9

Page Number: n/a

Previous change:

423.5.9. Sanitary facilities support systems. Support systems for the temporary sanitation facilities (e.g. bladders, storage tanks or vessels, etc.) shall be capable of supplying water and containing waste for the design capacity of the tornado shelter.

Historical information:

The language was added by the SSTC committee due to concern expressed that ICC 500 was not specific enough in spelling out the support systems for temporary sanitation facilities would need to meet the design capacity of a shelter.

The language did not exist in the 2018 IBC and the committee chose to carry the change forward in the rules. The language does not exist in the 2021 code.

Staff recommends the committee determine if the change should be kept as written, further modified, or deleted from the agency rules.