



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [BEBF 23](#)

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 04/28/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: SSTC 2015

Code Modified: 2018 IBC

Original Comment Form Number: SSTC 3

Rule Number: 748:20-2-9 (25)

Which area of the code (Section, Table, Figure) was revised?

IBC Section 423.5.11

Page Number: n/a

Previous change:

423.5.11 First aid kit. An ANSI compliant first aid kit rated for the number of storm shelter occupants, as listed in the construction documents, shall be supplied in all tornado shelters.

Historical information:

The language was added by the SSTC committee to require first aid kits in all community shelters to be ANSI rated for the number of occupants in the shelter. There was concern that while ICC 500 required first aid kits, it didn't specify they should be capable of serving the users of the shelter.

The language did not exist in the 2018 IBC and the 2018 BEBF committee after discussion on the ability to enforce the requirement, chose to carry the change forward in the rules. The language does not exist in the 2021 code.

Staff recommends the committee determine if the change should be kept as written, further modified, or deleted from the agency rules.