



OKLAHOMA

Uniform Building Code Commission Staff Comment Form - [BEBF 31](#)

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 05/09/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: BEBF 2018

Code Modified: 2018 IBC

Original Comment Form Number: SCF-107

Rule Number: 748:20-2-14 (5)

Which area of the code (Section, Table, Figure) was revised?

IBC Ch 9, Section 916.7

Page Number: 2021 IBC 9-42 and 2021 IFC 9-51
9-42

Previous change:

916.7 Gas sampling. Gas sampling shall be performed continuously. Sample analysis shall be processed immediately after sampling, except as follows:

- (1) For HPM gases, sample analysis shall be performed at intervals not exceeding 30 minutes.
- (2) For toxic gases that are not HPM, sample analysis shall be performed at intervals not exceeding 5 minutes, in accordance with Section 6004.2.2.7 of the International Fire Code®.
- (3) Where a less frequent or delayed sampling interval is approved.

Historical information:

This change was made in the 2018 adoption to address errata published by ICC. The language has been corrected in the 2021 edition. Staff recommendation is to delete the modification from the agency's rules and revert to the published language in the code.