

# Uniform Building Code Commission Staff Comment Form - <u>BEBF 36</u>

## **BEBF Technical Committee**

Review of the 2021 Editions of the International Building Code<sup>®</sup> (IBC<sup>®</sup>), International Existing Building Code<sup>®</sup> (IEBC<sup>®</sup>), International Fire Code<sup>®</sup>

Phone: 405-521-6501

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

### **Contact Information:**

Name: OUBCC StaffDate 05/10/23

Email: Kathy.Hehnly@oubcc.ok.gov

# Code Change Information

| Originating Committee: <u>BEBF 2018</u> | Code Modified: 2018 IBC  |
|---|--------------------------|
| Original Comment Form Number: SCF-113   | Rule Number: 748:20-2-20 |

## Which area of the code (Section, Table, Figure) was revised?

| IBC Ch 15, Section 1512.2.1.1 | Page Number: <u>2021 IBC 15-19</u> |
|-------------------------------|------------------------------------|
|-------------------------------|------------------------------------|

### Previous change:

**1512.2.1.1 Exceptions**. A roof recover shall not be permitted where any of the following conditions occur:

(1) Where the existing roof or roof covering is water soaked or has deteriorated to the point that the existing roof or roof covering is not adequate as a base for additional roofing.

(2) Where the existing roof covering is slate, clay, cement or asbestos-cement tile.

(3) Where the existing roof has two or more applications of any type of roof covering.

(4) Where the existing roof has one or more applications of asphalt shingles, additional applications of asphalt shingles shall not be permitted.

#### Historical information:

This change was made by the 2018 BEBF committee. In the 2018 code the section reference is 1511.3.1.1. The change was submitted to keep the code consistent with the adoption of the IRC which prohibits the installation of asphalt shingles over the top of existing asphalt shingles.

The added language does not exist in the 2021 code. The section has been moved in the 2021 code and is 1512.2.1.1. Staff recommendation is to review the change and determine if it should be kept as written, modified or removed from the agency's rules.