



**Uniform Building Code Commission
Staff Comment Form - [BEBF 37](#)**

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 05/10/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: BEBF 2018

Code Modified: 2018 IBC

Original Comment Form Number: CCF-119

Rule Number: 748:20-2-21 (1)

Which area of the code (Section, Table, Figure) was revised?

IBC Ch 16, Section 1604.10

Page Number: 2021 IBC 16-4

Previous change:

1604.10 Loads on storm shelters. Loads and load combinations on storm shelters shall be determined in accordance with Section 423.5.3 and ICC 500®.

Historical information:

This change was made by the 2018 BEBF committee. The submitter noted it added a pointer to the modification made in Section 423.5.3 and clarified that roof live loads on storm shelters could not be reduced as allowed for other structures in Section 1607.13.2.1.

The added language does not exist in the 2021 code. Staff recommendation is to review the change and determine if it should be kept as written, modified or removed from the agency's rules.