



OKLAHOMA

Uniform Building Code Commission Staff Comment Form – **BEBF 54**

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 05/10/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: BEBF 2018

Code Modified: 2018 IFC

Original Comment Form Number: CCF-139

Rule Number: 748:20-4-6 (5), (6), & (7)

Which area of the code (Section, Table, Figure) was revised?

IFC Chapter 1 Sections 105.5.14 and 105.6.6

Page Number: 2021 IFC 1-11

Previous change:

105.6.51 Energy storage systems. An operational permit is required for stationary and mobile energy storage systems regulated by Section 1206.

105.7.2 Battery Energy storage systems. A construction permit is required to install stationary energy storage battery systems regulated by Section ~~1206.2~~ 1206.

105.7.3 Capacitor energy storage systems. A construction permit is required to install capacitor energy storage systems regulated by Section ~~1206.3~~. This section has been stricken from the code.

Historical information:

The change was made in the 2018 IFC as part of an over-arching change to update chapter 12 of the IFC to reflect the (at the time) pending updates in the 2021 code. The 2021 and 2024 codes reflects the changes made above. Staff recommendation is to delete the modifications from the agency rules and revert to the published code in the 2021 edition.