



Uniform Building Code Commission
Staff Comment Form – BEBF 58
BEFB Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 05/10/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: BEFB 2018

Code Modified: 2018 IFC

Original Comment Form Number: AFPTC
44 & 45

Rule Number: 748:20-4-7(6) and (15)

Which area of the code (Section, Table, Figure) was revised?

IFC Chapter 2 Definitions

Page Number: 2021 IFC 2-8

Previous change:

DISPENSING AREA. The appropriate hazardous (classified) locations for the fuel being dispensed in accordance with the National Electrical Code® – NFPA® 70.

MAIN RAILROAD TRACK. That part of the railway, exclusive of switch tracks, branches, yards, and terminals upon which trains are operated by timetable or train order or both.

Historical information:

Both terms were originally added by the Alternative Fuels Technical Committee and were kept in the code during the 2018 review process. Neither term appears in the 2021 code. However, the 2021 code does contain two new terms for "Dispensing" and "Dispensing Device, Overhead Type." Both terms should be reviewed in conjunction with the term for the "Dispensing Area" to determine if it should be kept and/or if either of the two new terms needs to be modified.