

# Uniform Building Code Commission Staff Comment Form – BEBF 64

## **BEBF Technical Committee**

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

#### **Contact Information:**

Name: OUBCC Staff Date 05/10/23

Email: Kathy.Hehnly@oubcc.ok.gov Phone: 405-521-6501

**Code Change Information** 

Originating Committee: BEBF 2015 Code Modified: 2018 IBC

Original Comment Form Number: <u>BEBF-52</u> Rule Number: <u>748:20-4-8 (5)</u>

Which area of the code (Section, Table, Figure) was revised?

<u>IFC Chapter 3, Table 315.7.6(1)</u> Page Number: <u>2021 IFC 3-9</u>

#### **Previous change:**

See table on next page

### **Historical information:**

This change was submitted by a 2018 technical committee member. After reviewing the error, and contacting ICC, the table was found to be in error, but it wasn't considered as "errata" as it was not a mistake by staff, rather the original submission contained an error, and the entire change would need to go back through the ICC process to be corrected.

The spacing between wood pallets in the table was reversed in the first two columns. The committee elected to correct the spacing requirements at the state level.

The 2021 code has been updated and corrected. In the 2024 code the table has been revised with several items no longer listed. Staff recommendation is to review the table and determine if it should be kept as written in the agency's rules or revert to the published code.

| WALL<br>CONSTRUCTION      | OPENING TYPE                                     | WOOD PALLET SEPRATION DISTANCE (feet) ≤ 50 Pallets | WOOD PALLET<br>SEPRATION<br>DISTANCE (feet)<br>51 to 200 Pallets | WOOD PALLET SEPRATION DISTANCE (feet) > 200 Pallets |
|---------------------------|--|--|--|---|
| Masonry                   | None   | 2  | 2  | 2   |
| Masonry                   | Fire-rated<br>glazing with<br>open<br>sprinklers | 2  | 5  | 20  |
| Masonry                   | Fire-rated glazing                               | <del>10</del> <u>5</u>                             | <del>5</del> <u>10</u>   | 20  |
| Masonry                   | Plane glass<br>with open<br>sprinklers           | <del>10</del> <u>5</u>                             | 5 <u>10</u>  | 20  |
| Noncombustible            | None   | <del>10</del> <u>5</u>                             | <del>5</del> <u>10</u>   | 20  |
| Wood with open sprinklers | -  | <del>10</del> <u>5</u>                             | 5 <u>10</u>  | 20  |
| Wood                      | None   | 15   | 20   | 90  |
| Any                       | Plane glass                                      | 15   | 30   | 90  |