



**Uniform Building Code Commission
Staff Comment Form – BEBF 67**

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 05/10/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: BEBF 2018

Code Modified: 2018 IBC

Original Comment Form Number: SCF 84

Rule Number: 748:20-4-11 (2)

Which area of the code (Section, Table, Figure) was revised?

IFC Chapter 6, Section 608.1

Page Number: 2021 IFC 6-8

Previous change:

608.1 General. Storage of cooking oil (grease) in commercial cooking operations utilizing above-ground tanks with a capacity greater than 60 gal (227 L) installed within a building shall comply with Section ~~610.2 through 610.7~~ 608.2 through 608.7 and NFPA 30. For purposes of this section, cooking oil shall be classified as a Class IIIB liquid unless otherwise determined by testing.

Historical information:

This change to the 2018 code was made to correct errata. The 2021 code is correct and staff recommendation is to delete the change from the agency's rules and revert to the published code language.