



OKLAHOMA

Uniform Building Code Commission Staff Comment Form – **BEBF 74**

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 05/10/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: AFPTC-2015

Code Modified: 2018 IFC

Original Comment Form Number: AFPTC12

Rule Number: 748:20-4-28 (1)

Which area of the code (Section, Table, Figure) was revised?

IFC Chapter 23, Section 2301.7

Page Number: 2021 IFC n/a

Previous change:

2301.7 Liquid natural gas motor fuel-dispensing facilities. Motor fuel-dispensing facilities utilizing liquid natural gas (LNG) fuel shall comply with the requirements of Section 2303 and Chapter 55.

Historical information:

This section was added to the 2015 code by the AFPTC. It was carried forward in the 2018 adoption. It was created to clarify that motor fuel-dispensing facilities for liquid natural gas (LNG) must comply with the requirements of Section 2303 and Chapter 55.

The language is not in the 2021 code. Staff recommendation is to keep it in the agency's rules.