



Uniform Building Code Commission
Staff Comment Form – BEBF 78
BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 05/12/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: AFPTC-2015

Code Modified: 2018 IFC

Original Comment Form Number: AFPTC 9

Rule Number: 748:20-4-28 (6)

Which area of the code (Section, Table, Figure) was revised?

IFC Ch 23, Section 2304.3.7

Page Number: 2021 IFC n/a

Previous change:

2304.3.7 Quantity limits. Dispensing equipment used at unsupervised locations shall comply with one of the following:

(A) Dispensing devices shall be programmed or set to limit uninterrupted fuel delivery to 25 gallons (95 L) and require a manual action to resume delivery. **Exception:** Dispensing devices that are equipped with a listed breakaway device or equal approved by the Authority Having Jurisdiction. Such emergency breakaway device shall be installed, maintained and replaced in accordance with the manufacturer's instructions.

(B) The amount of fuel being dispensed shall be limited in quantity by a preprogrammed card as approved.

Historical information:

The exception was added by the AFPTC to address the filling of large fleet vehicles, "tank trailers" with large capacities and the fill-time delivery limits. The requirement of a 25-gallon delivery limit was determined to be impractical in those types of dispensing applications. The language does not exist in the 2021 code.

The language is not in the 2021 code. Staff recommendation is to keep it in the agency's rules.