



**Uniform Building Code Commission**  
**Staff Comment Form – BEBF 79**  
**BEBF Technical Committee**

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

**Contact Information:**

Name: OUBCC Staff

Date 05/12/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

**Code Change Information**

Originating Committee: AFPTC-2015

Code Modified: 2018 IFC

Original Comment Form Number: AFPTC14

Rule Number: 748:20-4-28 (7) & 748:20-4-66(1)

**Which area of the code (Section, Table, Figure) was revised?**

IFC Ch 23, Section 2307.3 & Ch 61, Section 6106.1

Page Number: 2021 IFC n/a

**Previous change:**

**2307.3 Attendants.** Motor fuel-dispensing operations for LP-gas shall be conducted by qualified attendants or in accordance with Section 2307.7 by persons trained in the proper handling of LP-gas. **Exception:** When the dispensing equipment meets the guidelines of NFPA® 58 for "Low emission transfer" an attendant is not required.

**6106.1 Attendants.** Dispensing of LP-gas shall be performed by a qualified attendant. **Exception:** When the dispensing equipment meets the guidelines of NFPA® 58 for "Low emission transfer" an attendant is not required.

**Historical information:**

The modification was made by the AFPTC to both sections address new technology for low-emission transfer dispensers for LP-gas. The language is not in the 2021 code. Staff recommendation is to keep it in the agency's rules.