



OKLAHOMA

Uniform Building Code Commission Staff Comment Form – **BEBF 80**

BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

NOTE: This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

Contact Information:

Name: OUBCC Staff

Date 05/12/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

Code Change Information

Originating Committee: AFPTC-2015

Code Modified: 2018 IFC

Original Comment Form Number: AFPTC
59R1

Rule Number: 748:20-4-28 (8)

Which area of the code (Section, Table, Figure) was be revised?

IFC Ch 23, Section 2307.4.1

Page Number: 2021 IFC n/a

Previous change:

2307.4.1 Low emission transfer. When the dispensing equipment is installed in accordance with Section 6.30.5 of NFPA® 58 for "Low emission transfer," the transfer distance requirements in Table 6.7.2.1 and Section 6.27.4.3 of NFPA® 58 shall be reduced by one-half.

Historical information:

The modification was made by the AFPTC to address new technology for low-emission transfer dispensers for LP-gas. The language is not in the 2021 code. Staff recommendation is to keep it in the agency's rules.