



# OKLAHOMA

## Uniform Building Code Commission Staff Comment Form – **BEBF 83**

### BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

#### Contact Information:

Name: OUBCC Staff

Date 05/15/23

Email: Kathy.Hehnly@oubcc.ok.gov

Phone: 405-521-6501

#### Code Change Information

Originating Committee: AFPTC-2015

Code Modified: 2018 IFC

Original Comment Form Number: AFPTC  
27 and 28

Rule Number: 748:20-4-28 (11)

#### Which area of the code (Section, Table, Figure) was be revised?

IFC Ch 23, Section 2308.4

Page Number: 2021 IFC 23-10

#### Previous change:

**2308.4 Private fueling of motor vehicles.** Self-service CNG dispensing systems, including key, code and card lock dispensing systems, shall be limited to the filling of approved, permanently mounted fuel containers ~~on CNG-powered vehicles.~~

In addition to the requirements in Section 2305, the owner of a self-service CNG motor fuel-dispensing facility shall ensure the safe operation of the system ~~and the training of users.~~

#### Historical information:

The modification was added by the AFPTC address current industry practices. Within the CNG industry "tube trailers" are commonly utilized when gas lines are down and are often permanently mounted to vehicles that are not CNG-powered. The committee determined that trailers had to meet the Dept of Transportation requirements before making the modification. They also considered it is the responsibility of the user of the CNG dispenser to be properly trained on their vehicle's filling procedures and that it should be up to the user, not the fuel station's owner to obtain training. The 2021 language includes the deleted language in the change above.