



# OKLAHOMA

## Uniform Building Code Commission Staff Comment Form – **BEBF 92**

### BEBF Technical Committee

Review of the 2021 Editions of the International Building Code® (IBC®), International Existing Building Code® (IEBC®), International Fire Code®

**NOTE:** This form and any attachments hereto are subject to the Oklahoma Open Records Act and may be disbursed, upon request, without further notice to the submitter.

#### Contact Information:

Name: OUBCC Staff

Date 05/15/23

Email: Kathy.Hehnlly@oubcc.ok.gov

Phone: 405-521-6501

#### Code Change Information

Originating Committee: BEBF 2018

Code Modified: 2018 IFC

Original Comment Form Number: CCF 101

Rule Number: 748:20-4-44 (16)

#### Which area of the code (Section, Table, Figure) was be revised?

IFC Ch 39, Section 3905.3

Page Number:

#### Previous change:

**3905.3 Emergency power system.** For extraction processes utilizing hydrocarbon gases or liquids as solvents, the extraction room lighting and extraction room ventilation system shall be provided with emergency power in accordance with Section 2702 of the International Building Code®.

#### Historical information:

The modification mirrors requirement in the 2018 NFPA 1, Section .38.6.2.3.5 and requires emergency power for lights and ventilation whenever hydrocarbons are used in the extraction process. This section is not in the 2021 code.