

From: [Paperform](#)
To: [Kathy Hehny](#)
Subject: [EXTERNAL] Code Change Proposal Form Submitted
Date: Monday, March 23, 2026 8:10:21 AM
Attachments: [69c13ba72e8ead86de03abe8.pdf](#)

CSPSTC-7

Code Change Proposal

Submitted At

03-23-2026 08:09:59

First & Last Name

John Gill

Street Address

420 West Main Street

City

Oklahoma City

State

Oklahoma

Zip Code

73102

Email

john.gill@okc.gov

Phone Number

+1 (405) 297-2371

Will this change increase the cost of construction?

NO

Which code needs to be revised?

2024 ISPSC

International Swimming Pool and Spa Code

Which section of the code needs to be revised?

Section: 325.10

Table:

Figure:

Page Number: 39

Paste your text into the box to show the proposed new, revised, or deleted text in Legislative format. Line through text to be deleted and underline text to be added or revised.

Existing:

325.10 Gaseous Chlorination space. Use of compressed chlorine gas shall be prohibited for new construction and after substantial alteration to existing facilities

Proposed:

325.10 Gaseous Chlorination space. Use of compressed chlorine gas shall be prohibited for new construction and after alteration to existing facilities.

State the purpose and reason for the change and provide substantiation to support the proposed change.

In light of the fact that it is rare to find a chlorine gas system for a pool or spa, to avoid the dangers and life safety hazards of chlorine gas it shall be removed whenever there are alterations to a facility.

Submission ID

69c13ba72e8ead86de03abe8